

Duration: 3hrs

[Max Marks: 80]

- N.B. :** (1) Question No 1 is Compulsory.  
 (2) Attempt any three questions out of the remaining five.  
 (3) All questions carry equal marks.  
 (4) Assume suitable data, if required and state it clearly.

- Q1. Answer the following** **20**
- a** Draw input-output curve, heat rate curve and incremental fuel cost curve and explain their importance in economic load dispatch.
- b** Derive characteristic equation and state the condition for steady state stability in power system.
- c** Write the static load flow equations and explain the classification of buses in power system.
- d** For an isolated single area, consider the data given below.  
 Load decreases by 1% for a decrease in frequency by 1%. Find the gain and time constant of the power system represented by a first order transfer function.  
 Total Area Capacity=1000 MW, Normal Operating Load = 500 MW, H = 5 sec, R= 2.5 Hz / pu MW, Operating Frequency =50 Hz.
- e** Draw the diagram to indicate interconnection between different operating states of power system and explain each operating state.
- Q 2. A** Derive the equation for optimum generation scheduling considering transmission losses (Exact coordinate equation) **10**
- Q 2. B** A synchronous generator is generating 20% of the maximum power it is capable of generating. If the mechanical input to the generator is increases by 250% of the previous value, calculate the maximum value of torque angle during the swing of rotor round the new equilibrium point. **10**
- Q3. A** Compare GS, NR and Fast decoupled load flow methods for solution of Static Load Flow Equations of a power system. **10**
- Q3. B** A constant load of 300 MW is supplied by two 200 MW generators, 1 and 2, for which the respective incremental fuel costs are **10**  
 $IC_1 = 0.1P_1 + 20$  Rs/MWh  
 $IC_2 = 0.12P_2 + 15$  Rs/MWh  
 with powers in MW and costs C in Rs/hr. Determine (a) the most economical division of load between the generators, and (b) the saving in Rs/day thereby obtained compared to equal load sharing between machines.
- Q4. A** Derive Swing equation for a synchronous machine that describes rotor dynamics. **10**
- Q 4. B** Find the steady state power limit of a system consisting of a generator equivalent reactance 0.50 pu connected to an infinite bus through a series reactance of 1.0 pu. The terminal voltage of the generator is held at 1.20 pu and the voltage of the infinite bus is 1.0 pu. **10**

**Q 5 A** Draw complete block diagram and explain dynamic response of Load frequency controller for an isolated power system with and without PI controller. **10**

**Q 5.B** For the following system generators are connected to all the four buses and loads are connected at buses 2 and 3. All buses other than slack bus are PQ buses. Assuming flat voltage start, determine the bus voltages at the end of first Gauss Seidel iteration. **10**

Line Bus to bus	Y(pu)
1-2	2-j6
1-3	1-j3
2-3	0.6667-j2
2-4	1-j3
3-4	2-j6

Bus	P(pu)	Q(pu)	V(pu)	Remarks
1	-	-	1.04<0°	Slack
2	0.5	-0.2	-	PQ
3	-0.1	0.5	-	PQ
4	0.3	-0.1	-	PQ

**Q 6. A** What is power pool? Explain the different types of energy transactions and interchanges in power system. **10**

**Q 6. B** Two generators rated 250 MW and 350 MW are operating in parallel. The droop characteristics of their governors are 4% and 5%, respectively from no load to full load. Assuming that the generators are operating at 50 Hz at no load, how would a load of 600 MW be shared between them? What will be the system frequency at this load? Assume free governor operation. **10**

\*\*\*\*\*